



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 6/29/09

Code 48.6-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R403.1.4.1 Frost protection		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change R403.1.4.1 as follows:</p> <p>(a) Delete exceptions 1. and 2. and substitute <u>1. Detached, detached carports or accessory structures built to the requirements of Table R309.</u></p> <p>(b) Renumber exception 3. as 2.</p>		
REASON AND FISCAL IMPACT		
<p>Brings forward text from the 2005 InRC that refers to the amendment table on accessory structures and removes language that conflicts with the table..</p> <p>Fiscal impact: no additional cost to construction.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		